

BERSCH CONSULTING LTD.

Air Monitoring Bulletin Regina Catholic School Division – St. Deshaye Project No: B85.17

August 16th, 2017

Facility Clearance Limit for Unprotected Workers = 0.01 Fibers per cc.

Sample	Date Sampled	Start Time	End Time	Flow L/M	Activity	Location	Fibers per cc.	Comments
5	08/16/17	08:44	11:18	2.119	St. Deshaye – Crawlspace Clean Up – Pipe Fitting and Debris Removal – HEPA Vacuuming and Glove Bagging	North East Crawl Space – Adjacent Work Area	0.0030	Fiber Level Acceptable. No Concerns Noted.
6	08/16/17	08:45	11:19	2.215	St. Deshaye – Crawlspace Clean Up – Pipe Fitting and Debris Removal – HEPA Vacuuming and Glove Bagging	North East Crawl Space – Adjacent Entry Door	0.0058	Fiber Level Acceptable. No Concerns Noted.

Note: Analyzed as per NIOSH 7400 Method for Sampling and Evaluating Airborne Asbestos Dust / Asbestos Fibers Counting - NIOSH 582E. Occupational Health & Safety of the Province of Saskatchewan regulations state where an asbestos process has been completed the air monitoring must verify that airborne fiber concentrations are less than 0.01 fibers per cubic centimetre of air.