

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10**CLIENT: REGINA CATHOLIC SCHOOL BOARD
MILLER COMPREHENSIVE HIGH SCHOOL
1027 COLLEGE AVENUE****BULK SAMPLE ANALYSIS REPORT**

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
1	06-01-10	North Crawlspace Transite Rainwater Leader	Chrysotile Crocidolite	20 5	BERSCH	BERSCH
2	06-01-10	North Crawlspace Pipefitting Compound - PWP Line	Chrysotile	40	BERSCH	BERSCH
3	06-01-10	North Crawlspace Pipefitting Compound - PWS Line	Chrysotile	40	BERSCH	BERSCH
4	06-01-10	North Crawlspace Pipefitting Compound - DCWS Line	Chrysotile	40	BERSCH	BERSCH
5	06-01-10	North Crawlspace Pipefitting Compound - DHW Line	Chrysotile	40	BERSCH	BERSCH
6	06-01-10	North Crawlspace Pipefitting Compound - PWS Line	Chrysotile	60	BERSCH	BERSCH
7	06-01-10	North Crawlspace Pipefitting Compound - CHWS Line	Chrysotile	60	BERSCH	BERSCH
8	06-01-10	Boiler Room Pipefitting Compound - DHW Line - North Wall	Chrysotile	60	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10**CLIENT: REGINA CATHOLIC SCHOOL BOARD****MILLER COMPREHENSIVE HIGH SCHOOL****1027 COLLEGE AVENUE****BULK SAMPLE ANALYSIS REPORT**

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
9	06-01-10	Boiler Room Pipefitting Compound - DHWR Line - North Wall	Chrysotile	60	BERSCH	BERSCH
10	06-01-10	Boiler Room Pipefitting Compound - PWR Line (Lg. Diam)	Chrysotile	60	BERSCH	BERSCH
11	06-01-10	Boiler Room Pipefitting Compound - PWR Line (Med Diam)	Chrysotile	40	BERSCH	BERSCH
12	06-01-10	Boiler Room pipefitting Compound - PWS Line (Lg. Diam)	Chrysotile	60	BERSCH	BERSCH
13	06-01-10	Boiler Room Pipefitting Compound - Sm. Diam - East Wall	None Detected		BERSCH	BERSCH
14	06-01-10	Boiler Room Duct Parging - Adj. Pump & Fan Control	Chrysotile	70	BERSCH	BERSCH
15	06-01-10	Boiler Room Parging - Dom. Hot Water Tank (North)	Chrysotile	70	BERSCH	BERSCH
16	06-01-10	Boiler Room Parging - Dom. Hot Water Tank (South)	Chrysotile	70	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
17	06-01-10	Boiler Room Boiler #7 - Lineal Pipe Insulation (Header)	Chrysotile	70	BERSCH	BERSCH
18	06-01-10	Boiler Room Duct Gasket - Adjacent Boiler #5	None Detected		BERSCH	BERSCH
19	06-01-10	Boiler Room Pipefitting Compound - Med. Diam	Chrysotile	60	BERSCH	BERSCH
20	06-01-10	Boiler Room Pipefitting Compound - HR Valve - Blr #7	None Detected		BERSCH	BERSCH
21	06-01-10	Boiler Room Gasket Material - Boiler #7	Chrysotile	80	BERSCH	BERSCH
22	06-01-10	Office - Adjacent Boiler Room 1' x 1' Ceiling Tile	None Detected		BERSCH	BERSCH
23	06-01-10	Office - Adjacent Boiler Room 2' x 4' Ceiling Tile	None Detected		BERSCH	BERSCH
24	06-01-10	Maintenance (Bob's Lounge) 2' x 4' Ceiling Tile	None Detected		BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
25	06-01-10	Maintenance (Bob's Lounge) Wall Plaster	None Detected		BERSCH	BERSCH
26	06-01-10	Basement - Men's Washroom (Adj. Blr Rm) 2' x 4' Ceiling Tile	None Detected		BERSCH	BERSCH
27	06-01-10	Basement - Men's Washroom (Adj. Blr Rm) 2' x 4' Ceiling Tile	None Detected		BERSCH	BERSCH
28	06-01-10	Basement - Men's Washroom (Adj. Blr Rm) Pipefitting Compound - Ceiling Space	Chrysotile	40	BERSCH	BERSCH
29	06-01-10	Basement - Boiler Room Corridor Duct Gasket - Adj. Bob's Lounge	None Detected		BERSCH	BERSCH
30	06-01-10	Middle Crawlspace Firestop Material - N. Wall Penetration (Grey)	Chrysotile	70	BERSCH	BERSCH
31	06-01-10	Middle Crawlspace Firestop Material - N. Wall Penetration (White)	Chrysotile	70	BERSCH	BERSCH
32	06-01-10	Middle Crawlspace Pipefitting Compound	Chrysotile	40	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

**CLIENT: REGINA CATHOLIC SCHOOL BOARD
MILLER COMPREHENSIVE HIGH SCHOOL
1027 COLLEGE AVENUE**

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
33	06-01-10	Basement Corridor Vinyl Floor Tile (Green w/ White)	Chrysotile	1 to 5	BERSCH	BERSCH
34	06-01-10	Basement Corridor Vinyl Floor Tile (Dk. Green w/ White)	Chrysotile	1 to 5	BERSCH	BERSCH
35	06-01-10	Basement Corridor Pipefitting Compound - West Wall	None Detected		BERSCH	BERSCH
36	06-01-10	Basement Corridor Duct Gasket - West (Dk. Green)	None Detected		BERSCH	BERSCH
37	06-01-10	Basement Corridor Vinyl Floor Tile (Teal w/ White)	None Detected		BERSCH	BERSCH
38	06-01-10	South Crawlspace Pipefitting Compound	Chrysotile	40	BERSCH	BERSCH
39	06-01-10	South Crawlspace Pipefitting Compound	Chrysotile	40	BERSCH	BERSCH
40	06-01-10	South Crawlspace Debris - Top of Vent - Adj. Fan Unit #12	Chrysotile	40	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
41	06-01-10	Middle Crawlspace Vermiculite Debris	Potential	Trace	BERSCH	BERSCH
42	06-01-10	Basement Corridor - Adj. Rooms 53 & 54 12" x 12" Vinyl Floor Tile (Brown w/ Beige)	None Detected		BERSCH	BERSCH
43	06-01-10	Main Office 2' x 4' Ceiling Tile	None Detected		BERSCH	BERSCH
44	06-01-10	Main Office - Photocopy Room Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
45	06-01-10	Main Office Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
46	06-01-10	Main Entrance - Adjacent Pop Machines Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
47	06-01-10	Student Services 2' x 2' Ceiling Tile	None Detected		BERSCH	BERSCH
48	06-01-10	Student Services 2' x 2' Ceiling Tile	None Detected		BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
49	06-01-10	Student Services Pipefitting Compound - Ceiling (Adj. Counsellor)	Chrysotile	60	BERSCH	BERSCH
50	06-01-10	Main Floor - East Corridor Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
51	06-01-10	Gym #1 - Stage 12" x 12" Vinyl Floor Tile (White w/ Orange)	None Detected		BERSCH	BERSCH
52	06-01-10	Room 182 - Home Economics 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
53	06-01-10	Main Floor - East Corridor Pipefitting Compound (Ceiling Adj. Rm 157)	Chrysotile	60	BERSCH	BERSCH
54	06-01-10	Main Concourse Ceiling Texture	Chrysotile	10	BERSCH	BERSCH
55	06-01-10	Room 171 12" x 12" Vinyl Floor Tile (White w/ Green)	None Detected		BERSCH	BERSCH
56	06-01-10	Room 190 (Across from C191) 12" x 12" Vinyl Floor Tile	Chrysotile	1 to 5	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
57	06-01-10	Main Corridor - Adjacent C191 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
58	06-01-10	Room C191 12" x 12" Vinyl Floor Tile (White w/ Grey)	None Detected		BERSCH	BERSCH
59	06-01-10	Lobby - Adjacent Art Room Pipefitting Compound (Ceiling)	Chrysotile	40	BERSCH	BERSCH
60	06-01-10	Art Room 12" x 12" Vinyl Floor Tile (Pale Green)	Chrysotile	1 to 5	BERSCH	BERSCH
61	06-01-10	Cafeteria Sheet Vinyl Floor (Marble)	Chrysotile	30	BERSCH	BERSCH
62	06-01-10	Cafeteria Sheet Vinyl Floor (Bright Blue)	None Detected		BERSCH	BERSCH
63	06-01-10	South Crawlspace Firestop Material	Chrysotile	70	BERSCH	BERSCH
64	06-01-10	Media Centre Spray-Applied Fireproofing	Chrysotile Amosite	20 40	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
65	06-01-10	Media Centre Pipefitting Compound - Adj. AHU-3 (sm. diam)	Chrysotile	60	BERSCH	BERSCH
66	06-01-10	Media Centre Pipefitting Compound - Adj. AHU-3 (med. diam)	Chrysotile	40	BERSCH	BERSCH
67	06-01-10	Room 132 - Media Centre Washroom Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
68	06-01-10	Corridor Between Rms 130 & 131 12" x 12" Vinyl Floor Tile (Grey)	None Detected		BERSCH	BERSCH
69	06-01-10	Music Room 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
70	06-01-10	Music Room - Storage Room 1' x 1' Ceiling Tile	None Detected		BERSCH	BERSCH
71	06-01-10	Music Room - Upper Fan Room Pipefitting Compound - South Wall	Chrysotile	20	BERSCH	BERSCH
72	06-01-10	Music Room - Upper Fan Room Pipefitting Compound	Chrysotile	20	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
73	06-01-10	Welding Shop Wall Board - Welding Stations	Chrysotile	30	BERSCH	BERSCH
74	06-01-10	Fan Room - Maintenance Storage (Tractor) Pipefitting Compound	Chrysotile	40	BERSCH	BERSCH
75	06-01-10	Fan Room - Carpentry Lab Pipefitting Compound	Chrysotile	60	BERSCH	BERSCH
76	06-01-10	Second Floor East Corridor Pipefitting Compound (Ceiling Adj. Rm 240)	Chrysotile	60	BERSCH	BERSCH
77	06-01-10	Room 283 Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
78	06-01-10	Room 280 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
79	06-01-10	Second Floor Corridor Adj. Rm 280 Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
80	06-01-10	Room B293 12" x 12" Vinyl Floor Tile	Chrysotile	1 to 5	BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

CLIENT: REGINA CATHOLIC SCHOOL BOARD

MILLER COMPREHENSIVE HIGH SCHOOL

1027 COLLEGE AVENUE

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
81	06-01-10	Corridor Adj. Room 230 Pipefitting Compound (Ceiling)	Chrysotile	40	BERSCH	BERSCH
82	06-01-10	North Crawlspace Lineal Pipe Insulation	Chrysotile	70	BERSCH	BERSCH
83	06-01-10	North Crawlspace Lineal pipe Insulation (CHWS Line)	Chrysotile	50	BERSCH	BERSCH
84	06-01-10	North Crawlspace Lineal Pipe Insulation (CHWS Line)	Chrysotile Amosite	40 20	BERSCH	BERSCH
85	06-01-10	Boiler Room - Work Shop Work Bench - Counter Top	Chrysotile	50	BERSCH	BERSCH
86	06-01-10	Boiler Room Stock Gasket Material Roll	Chrysotile	80	BERSCH	BERSCH
87	06-01-10	South Crawlspace Rope Gasket - Duct Shaft	None Detected		BERSCH	BERSCH
88	06-01-10	Boiler Room Ceiling Tile - Loose Tile in Storage	None Detected		BERSCH	BERSCH

Bersch & Associates Ltd.

P.O Box 3568

Humboldt, Sk. S0K 2A0

PROJECT NO. R01.10

**CLIENT: REGINA CATHOLIC SCHOOL BOARD
MILLER COMPREHENSIVE HIGH SCHOOL
1027 COLLEGE AVENUE**

BULK SAMPLE ANALYSIS REPORT

NO.	DATE	SAMPLE INFORMATION	ASBESTOS	%	ANALYST	SAMPLER
89	06-01-10	Room 283 - Science Lab Black Counter Top	Chrysotile	30	BERSCH	BERSCH
90	06-01-10	Corridor Adjacent Room 291 Pipefitting Compound	Chrysotile	70	BERSCH	BERSCH