

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10****CLIENT: REGINA CATHOLIC SCHOOL BOARD****ARCHBISHOP M.C. O'NEILL HIGH SCHOOL****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
1	06-04-10	Boiler Room Boiler #1 - Lineal Pipe Insulation (North)	Chrysotile	70	BERSCH	BERSCH
2	06-04-10	Boiler Room Boiler #1 - Boiler Exhaust	Chrysotile	70	BERSCH	BERSCH
3	06-04-10	Boiler Room Hot Water Tank - Parging Compound	Chrysotile	60	BERSCH	BERSCH
4	06-04-10	Boiler Room Old Area Convertor - Parging Compound	Chrysotile	70	BERSCH	BERSCH
5	06-04-10	Boiler Room White Vessel (Adj. B22) - Parging Compound	None Detected		BERSCH	BERSCH
6	06-04-10	Boiler Room Pipefitting Compound (Adj. Blr #2 SW)	None Detected		BERSCH	BERSCH
7	06-04-10	Boiler Room Duct Gasket - South	None Detected		BERSCH	BERSCH
8	06-04-10	Boiler Room Pipefitting Compound (Green - Adj Hot Water Tank)	Chrysotile	10	BERSCH	BERSCH

# ***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10**

**CLIENT: REGINA CATHOLIC SCHOOL BOARD**

**ARCHBISHOP M.C. O'NEILL HIGH SCHOOL**

## **BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
9	06-04-10	Boiler Room Pipefitting Compound (Green PWS Line)	Chrysotile	20	BERSCH	BERSCH
10	06-04-10	Boiler Room Pipefitting Compound (Yellow CHS Line)	Chrysotile	20	BERSCH	BERSCH
11	06-04-10	Boiler Room Lineal Pipe Insulation (Yellow Steam Header)	Chrysotile	20	BERSCH	BERSCH
12	06-04-10	Boiler Room Pipefitting Compound (Brown - N. Side Boilers)	None Detected		BERSCH	BERSCH
13	06-04-10	Boiler Room Pipefitting Compound (Steam Supply Line)	None Detected		BERSCH	BERSCH
14	06-04-10	Boiler Room Lineal Pipe Insulation (West Wall)	Chrysotile	70	BERSCH	BERSCH
15	06-04-10	Boiler Room Boiler #1 - Rope Gasket	None Detected		BERSCH	BERSCH
16	06-04-10	Crawlspace Pipefitting Compound (Adj. Entrance)	None Detected		BERSCH	BERSCH

# ***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10**

**CLIENT: REGINA CATHOLIC SCHOOL BOARD**

**ARCHBISHOP M.C. O'NEILL HIGH SCHOOL**

## **BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
17	06-04-10	Crawlspace Pipefitting Compound (West Wall)	None Detected		BERSCH	BERSCH
18	06-04-10	Crawlspace Transite Rainwater Leader	Chrysotile Crocidolite	30 5	BERSCH	BERSCH
19	06-04-10	Fan Room Firestop - NE Corner Wall Penetration	Chrysotile	40	BERSCH	BERSCH
20	06-04-10	Maintenance Lunch Room 9" x 9" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
21	06-04-10	Basement Corridor (Adjacent Elevator) 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
22	06-04-10	Basement - NE Storage Room Pipefitting Compound (North Wall)	None Detected		BERSCH	BERSCH
23	06-04-10	Basement - NE Storage Room 2' x 4' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH
24	06-04-10	Basement - NE Storage Room 1' x 1' Ceiling Tile	None Detected		BERSCH	BERSCH

# ***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10**

**CLIENT: REGINA CATHOLIC SCHOOL BOARD**

**ARCHBISHOP M.C. O'NEILL HIGH SCHOOL**

## **BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
25	06-04-10	Basement - NE Storage Room 2' x 4' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH
26	06-04-10	Basement - Music Storage Room 1' x 1' Wall Panels	None Detected		BERSCH	BERSCH
27	06-04-10	Basement - Music Storage Room 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
28	06-04-10	Classroom 016 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
29	06-04-10	Industrial Arts Room 020 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
30	06-04-10	Entrance to IA Room 020 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
31	06-04-10	Entrance to IA Room 020 Light Fixture Heat Shield Material	Chrysotile	80	BERSCH	BERSCH
32	06-04-10	Industrial Arts Room 020 2' x 2' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH

# ***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10**

**CLIENT: REGINA CATHOLIC SCHOOL BOARD**

**ARCHBISHOP M.C. O'NEILL HIGH SCHOOL**

## **BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
33	06-04-10	Drama Room 028 Pipefitting Compound (Ceiling Space SW)	Chrysotile	40	BERSCH	BERSCH
34	06-04-10	Drama Room 028 Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
35	06-04-10	Music Room 3 Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
36	06-04-10	Music Room 3 1' x 1' Ceiling Tile	None Detected		BERSCH	BERSCH
37	06-04-10	Gymnasium 1 - Storage Room 9" x 9" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
38	06-04-10	Boy's Washroom (Adj. New Gym) 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
39	06-04-10	Corridor Adj. Resource Centre Pipefitting Compound (Ceiling Space)	None Detected		BERSCH	BERSCH
40	06-04-10	Fan Room (Adj. old Gym Storage Room) Pipefitting Compound (Roof Drain Line)	None Detected		BERSCH	BERSCH

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10****CLIENT: REGINA CATHOLIC SCHOOL BOARD****ARCHBISHOP M.C. O'NEILL HIGH SCHOOL****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
41	06-04-10	Main Floor - Student Commons Area Sheet Vinyl Floor	Chrysotile	40	BERSCH	BERSCH
42	06-04-10	Janitor / Storage Room Pipefitting Compound (South Wall)	None Detected		BERSCH	BERSCH
43	06-04-10	Storage Room 242 9" x 9" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
44	06-04-10	Classroom 212 Fume Hood Liner Panel	Chrysotile	30	BERSCH	BERSCH
45	06-04-10	Aboriginal Studies Room 240 Sheet Vinyl Floor	Chrysotile	30	BERSCH	BERSCH
46	06-04-10	Boiler Room Pipefitting Compound (DCWH Line)	Chrysotile	40	BERSCH	BERSCH
47	06-04-10	Boiler Room Pipefitting Compound (Yellow Humidifier Line)	Chrysotile	40	BERSCH	BERSCH
48	06-04-10	Boiler Room Pipefitting Compound (Yellow Codensate Line)	Chrysotile	40	BERSCH	BERSCH

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.10****CLIENT: REGINA CATHOLIC SCHOOL BOARD****ARCHBISHOP M.C. O'NEILL HIGH SCHOOL****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
49	06-04-10	Boiler Room Pipefitting Compound (HWS Line)	None Detected		BERSCH	BERSCH
50	06-04-10	Industrial Arts Room 020 Plaster Ducting	None Detected		BERSCH	BERSCH
51	06-04-10	Auditorium Stage Pipefitting Compound (Black Line NE)	Chrysotile	40	BERSCH	BERSCH
52	06-04-10	Classroom 207 Counter Top	Chrysotile	40	BERSCH	BERSCH