



Regina Catholic Schools

www.rcsd.ca

Michael A. Riffel Catholic High School

5757 Rochdale Blvd.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: t.ottenbreit@rcsd.ca

Date of Inventory: November 2010

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile Crocidolite	Throughout Building	Rain water leader CH20% CR5%		All accessible locations marked with RED spray paint. All other locations assumed to have ACM
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM