



# Regina Catholic Schools

[www.rcsd.ca](http://www.rcsd.ca)

## St. Augustine

2343 Edgar Ave.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: [t.ottenbreit@rcsd.ca](mailto:t.ottenbreit@rcsd.ca)

Date of Inventory: May 2013

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile	Basement – Boys washroom	Pipefitting Compound 75%	Above ceiling tiles Maintenance only	All accessible locations marked with RED spray paint. All other locations assumed to have ACM
Chrysotile	Gymnasium and storage rooms	Transite Rainwater Leader CH-30%	Upper level of gym Or behind locked doors	All accessible locations marked with RED spray paint except upper level of gym. All other locations assumed to have ACM
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM