



Regina Catholic Schools

THE BOARD OF EDUCATION OF THE REGINA ROMAN CATHOLIC SEPARATE SCHOOL DIVISION NO. 81

Bob Kowalchuk
Chair

Domenic Scuglia
Director of Education

Mr. Jason Hilderman
Occupation Health Officer
Jason.Hilderman@gov.sk.ca

Notice of Dangerous Occurrence

OH&S Regulation 9(3)

(a) Name of Employers and Contractor

- a. Regina Catholic School Division

(b) Date, Time and Location of Dangerous Occurrence

- a. Wednesday, March 27, 2018. 10 am. 150 Brotherton Ave. Regina, Saskatchewan

(c) Circumstances related to the occurrence

- a. Facilities Department Carpenters were beginning to remove existing ceiling tiles throughout the hallways of the school and noticed a pile of debris on the top of one of the tiles underneath a plumbing vent that had been drilled through an interior wall. The trained carpenters determined that it looked like vermiculite, so the tile was replaced while they went to get their PPE and Hepa Vac for clean-up. A review of the rest of the hallway ceiling space was performed on the next non-school day by the same carpenters to determine if there were additional areas of concern. There was also an electrician and the school principal in the area when the first pile of debris was discovered. Due to timing and work load a contractor was then brought in over the Easter Break to facilitate the replacement of all remaining ceiling tiles throughout the hallways in the un-occupied school.

(d) Contact Person

- a. Tyler Ottenbreit – Facilities Supervisor, Regina Catholic School Division.
- b. Cell Phone - 306-551-8896 Fax – 306-791-1740

Signed,

Tyler Ottenbreit
Facilities Supervisor
Regina Catholic School Division