



# Regina Catholic Schools

[www.rcsd.ca](http://www.rcsd.ca)

## St. Francis

45 Mikkelson Dr.  
Regina, Sk.

Contact Person: Tyler Ottenbreit  
Telephone: 306-791-7213

Title: Facilities Supervisor  
Email: [t.ottenbreit@rcsd.ca](mailto:t.ottenbreit@rcsd.ca)

Date of Inventory: May 2013

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile	Throughout building	Transite Rainwater Leader CH-30%		All accessible locations marked with RED spray paint. All locations considered to have ACM
Chrysotile	Community school Coordinator washroom	Light Heat Shield 70%	Ceiling height Maintenance only	
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM