



Regina Catholic Schools

www.rcsd.ca

St. Marguerite

2910 E Shooter Dr.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: t.ottenbreit@rcsd.ca

Date of Inventory: October 2012

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile	Throughout building	Transite Rainwater Leader CH-30%		All locations considered to have ACM
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM