

BERSCH CONSULTING LTD.

Air Monitoring Bulletin Regina Catholic School Division – St. Mathew Project No: B85.17

August 18th, 2017

Facility Clearance Limit for Unprotected Workers = 0.01 Fibers per cc.

Sample	Date Sampled	Start Time	End Time	Flow L/M	Activity	Location	Fibers per cc.	Comments
11	08/18/17	08:42	11:41	2.211	St. Mathew – Gymnasium – Rain Leader Insulation Removal – HEPA Vacuuming and Glove Bagging	Gymnasium – Adjacent East Door	0.0006	Fiber Level Acceptable. No Concerns Noted.
12	08/18/17	08:46	11:43	2.209	St. Mathew – Gymnasium – Rain Leader Insulation Removal – HEPA Vacuuming and Glove Bagging	Gymnasium – Adjacent Work Area	0.0013	Fiber Level Acceptable. No Concerns Noted.

Note: Analyzed as per NIOSH 7400 Method for Sampling and Evaluating Airborne Asbestos Dust / Asbestos Fibers Counting - NIOSH 582E. Occupational Health & Safety of the Province of Saskatchewan regulations state where an asbestos process has been completed the air monitoring must verify that airborne fiber concentrations are less than 0.01 fibers per cubic centimetre of air.