

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.12****CLIENT: REGINA CATHOLIC SCHOOLS****ST. MICHAEL SCHOOL****431 HAMILTON STREET****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
1	10/17/12	St. Michael Corridor Stipple Ceiling Texture	Chrysotile	20	BERSCH	BERSCH
2	10/17/12	St. Michael Nurse's Room Stipple Ceiling Texture	Chrysotile	20	BERSCH	BERSCH
3	10/17/12	St. Michael Staff Room Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
4	10/17/12	St. Michael Corridor 2' x 4' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH
5	10/17/12	St. Michael Caretaker's Room 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
6	10/17/12	St. Michael Caretaker's Room 2' x 2' Ceiling Tile	None Detected		BERSCH	BERSCH
7	10/17/12	St. Michael Corridor Duct Tape on Ducting	Chrysotile	5	BERSCH	BERSCH
8	10/17/12	St. Michael Corridor Duct Expansion Canvass	Chrysotile	25	BERSCH	BERSCH

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.12****CLIENT: REGINA CATHOLIC SCHOOLS****ST. MICHAEL SCHOOL****431 HAMILTON STREET****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
9	10/17/12	St. Michael Room 18 Transite Rainwater Leader	Chrysotile	30	BERSCH	BERSCH
10	10/17/12	St. Michael Basement Corridor Pipefitting Compound	None Detected		BERSCH	BERSCH
11	10/17/12	St. Michael Main Entrance Sheet Vinyl Floor	Chrysotile	30	BERSCH	BERSCH
12	10/17/12	St. Michael Mechanical Room (Adjacent Gym) Pipefitting Compound	Chrysotile	30	BERSCH	BERSCH
13	10/17/12	Mother Theresa Corridor Stipple Ceiling Texture	Chrysotile	15	BERSCH	BERSCH
14	10/17/12	Mother Theresa Corridor 2' x 4' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH
15	10/17/12	Mother Theresa Storage Room (Adjacent Furnace Rm) Sheet Vinyl Floor	None Detected		BERSCH	BERSCH
16	10/17/12	Mother Theresa Uniform Storage Room 9" x 9" Vinyl Floor Tile	Chrysotile	1 to 5	BERSCH	BERSCH

***Bersch & Associates Ltd.***

P.O Box 3568

Humboldt, Sk. S0K 2A0

**PROJECT NO. R01.12****CLIENT: REGINA CATHOLIC SCHOOLS****ST. MICHAEL SCHOOL****431 HAMILTON STREET****BULK SAMPLE ANALYSIS REPORT**

<b>NO.</b>	<b>DATE</b>	<b>SAMPLE INFORMATION</b>	<b>ASBESTOS</b>	<b>%</b>	<b>ANALYST</b>	<b>SAMPLER</b>
17	10/17/12	Mother Theresa Boy's Washroom Pipefitting Compound	Chrysotile	80	BERSCH	BERSCH
18	10/17/12	Mother Theresa Boy's Washroom 2' x 4' Suspended Ceiling Tile	None Detected		BERSCH	BERSCH
19	10/17/12	Mother Theresa Room 6 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
20	10/17/12	Mother Theresa Multi-Purpose Area 12" x 12" Vinyl Floor Tile	None Detected		BERSCH	BERSCH
21	10/17/12	Mother Theresa South Corridor Pipefitting Compound	Chrysotile	30	BERSCH	BERSCH
22	10/17/12	Mother Theresa South Corridor Transite Rainwater Leader	Chrysotile	30	BERSCH	BERSCH
23	10/17/12	Mother Theresa Gymnasium Storage Room Pipefitting Compound	Chrysotile	40	BERSCH	BERSCH
24	10/17/12	Mother Theresa Gymnasium Vinyl Floor Tile	None Detected		BERSCH	BERSCH