



Regina Catholic Schools

www.rcsd.ca

St. Theresa

2707 – 7th Ave E.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: t.ottenbreit@rcsd.ca

Date of Inventory: October 2012

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile	Boiler room	Vessel insulation	Behind locked door Maintenance only	All accessible locations marked with RED spray paint. All other locations assumed to have ACM
Chrysotile Crocidolite	Throughout building	Transite Rainwater Leader CH25% CR5%		All accessible locations marked with RED spray paint. All locations assumed to have ACM
Chrysotile	Gym, all storage rooms, staff washrooms, kindergarten washroom	Flooring Tile 1-5% Sheet 40%	Sealed floor	Good - moderate condition and recommended to manage in place until renovation warrants removal
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM