

April 17, 2019

Regina Catholic School Board  
2160 Cameron St,  
Regina, SK  
S4T 2V6

**ATTENTION: Tyler Ottenbreit**

**SUBJECT: Bulk Sample Analysis Report – St Timothy’s School**

Please find attached the laboratory results for the bulk sample collected on April 11, 2019 from the St Timothy’s School in Regina, Sk. The sample was analyzed for the identification of asbestos. Asbestos was detected within the sample.

The results for the sample submitted were obtained by examination in accordance with the current USEPA 600/R-93/116 Method for the analysis of asbestos in building materials using polarized light microscopy and dispersion staining techniques. The detection limit of this method is listed as less than 1% by volume.

This test report relates only to the materials sent for examination and any use or extension of the information by the client of these results is the responsibility of the client.

If any questions arise on the results of the attached information, please contact our office. Thank you for this opportunity of service.

Sincerely,



Evan Westad  
Bersch Consulting Ltd.  
B85BLD111- St. Timothy’s School

## Bulk Sample Analysis Report

April 17, 2019

Project Number: B85.19

Client: Regina Catholic Schools

Contact: Tyler Ottenbreit

Location: St Timothy's School

File Number: B85BAD11I

Sample Number	Sample Date	Sample Material	Sample Location and Information	Asbestos	%	Analyst
1	2019-04-11	Drywall Mud Compound	St Timothy's School- Boys Washroom/Changeroom	Chrysotile	2%	EMSL

**Note:** The results for the samples submitted were obtained by examination in accordance with the current USEPA 600/R-93/116 Method for the analysis of asbestos in building materials using polarized light microscopy and dispersion staining techniques. The detection limit of this method is listed as less than 1% by volume.