



Regina Catholic Schools

www.rcsd.ca

Jean Vanier

425 – 15th Ave.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: t.ottenbreit@rcsd.ca

Date of Inventory: May 2013

1. Type of Asbestos-Containing Material	2. Location in Facility	3. Characteristics	4. Accessibility	5. Comments
Chrysotile	Crawlspace	Pipefitting Compound 25-30%	Behind locked door Maintenance only	All accessible locations marked with RED spray paint. All other locations assumed to have ACM
Chrysotile	Crawlspace	Transite Rainwater Leader CH-30%	Behind locked door Maintenance only	All accessible locations marked with RED spray paint. All other locations assumed to have ACM
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM