

Deshaye Catholic School

37 Cameron Cres. Regina, Sk.

Contact Person: Tyler Ottenbreit Title: Facilities Supervisor

Telephone: 306-791-7213 Email: t.ottenbreit@rcsd.ca

Date of Inventory: October 2012

1. Type of Asbestos-	2. Location in	3. Characteristics	4. Accessibility	5. Comments
Containing Material	Facility			
Chrysotile	Crawlspace	Pipefitting Compound	Behind locked door	All accessible locations marked with RED
		10-30%	Maintenance only	spray paint. All other locations assumed to
				have ACM
Chrysotile	Crawlspace	Transite Rainwater	Behind locked door	All accessible locations marked with RED
		Leader	Maintenance only	spray paint. All other locations assumed to
		CH-20%		have ACM
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have
				ACM