

## St. Josaphat

140 Greenwood Cres. Regina, Sk.

Contact Person: Tyler Ottenbreit Title: Facilities Supervisor

Telephone: 306-791-7213 Email: t.ottenbreit@rcsd.ca

Date of Inventory: May 2013

1. Type of Asbestos-	<ol><li>Location in Facility</li></ol>	<ol><li>Characteristics</li></ol>	4. Accessibility	5. Comments
Containing Material				
Chrysotile	Basement –	Fire stop material	Behind locked door	All accessible locations marked with
	Boiler Room/Crawlspace	60-75%	Maintenance Only	RED spray paint. There may also be more under the yellow insulation
Chrysotile	Throughout building	Transite Rainwater Leader CH-30%		All locations considered to have ACM
Chrysotile	Kindergarten, Multi-purpose rm, Learning Resource washroom	Flooring 30%	Sealed floor	All in good condition and recommended to manage in place until renovation warrants removal
	Painted boards around exterior windows			Not tested but assumed to be ACM. Test before disturbing
Vermiculite	Throughout	Block walls		All concrete block walls are assumed to have ACM