



Regina Catholic Schools

www.rcsd.ca

St. Jerome

770 Rink Ave.

Regina, Sk.

Contact Person: Tyler Ottenbreit

Telephone: 306-791-7213

Title: Facilities Supervisor

Email: t.ottenbreit@rcsd.ca

Date of Inventory: May 2013

| 1. Type of Asbestos-Containing Material | 2. Location in Facility | 3. Characteristics | 4. Accessibility | 5. Comments |
|---|---|--|--|---|
| Chrysotile | Boiler Room- pipe penetrations into West wall by electrical | Fire stop Material 25% | Behind locked door Maintenance only | All accessible locations marked with RED spray paint. All other locations assumed to have ACM |
| Chrysotile | Throughout building | Transite Rainwater Leader CH-30% | | All locations considered to have ACM |
| Chrysotile | Kindergarten, Rm 1&2 washroom, workrooms in 5&6 and 7&8, Nurses room, Multi-purpose room, Staff washrooms | Flooring 40% | Sealed floor | All in good condition and recommended to manage in place until renovation warrants removal |
| Vermiculite | Throughout | Block walls | | All concrete block walls are assumed to have ACM |